



Product Service

Compliance Document

No. D 103237 0006 Rev. 00

Holder of Certificate: **CSUNPOWER Technology (Nanjing) Co., Ltd**

10F, Building B4
No.19, Suyuan Avenue, Jiangning District
211106 Nanjing
PEOPLE'S REPUBLIC OF CHINA

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules
Mono-Crystalline Silicon Photovoltaic Module**

Model(s): **CSP17-72HxxxW (xxx=420-450, in step of 5)
CSP17-60HxxxW (xxx=355-375, in step of 5)
CSP16-72HxxxW (xxx=385-415, in step of 5)
CSP16-60HxxxW (xxx=325-345, in step of 5)
xxx is standing for rated output power at STC.**

Parameters:

| | |
|-------------------------|---|
| Construction: | Framed, with Junction box, Cable and Connectors. |
| Safety Class: | Class II |
| Maximum System Voltage: | 1500 or 1000 V DC |
| Remark: | Modules listed above comply with the requirements of being non-sensitive to LeTID. |

Tested according to: IEC 61215-1 draft, clause A.16, version 2019-04-02
IEC 61215-2 draft, clause 4.22.1, version 2019-04-02

This Compliance document confirms the compliance with the listed standards on a voluntary basis. It refers only to the sample submitted for testing and certification and does not certify the quality or safety of the serial products. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062010404-00

Date, 2020-08-26

(Zhulin Zhang)